

## ADDENDUM | No. 3

<b>PROJECT</b>	Training Academy, Exterior Upgrades – Roof Replacement South Dakota State Penitentiary Sioux Falls, South Dakota OSE # C1218 - - 05X/SWMR	
<b>BID DATE</b>	2:00 PM CT	April 24, 2018
<b>BID LOCATION</b>	Office of the State Engineer Joe Foss Building 523 East Capitol Pierre, SD 57501 - 3182	
<b>ISSUE DATE</b>	April 23, 2018	
<b>NOTICE</b>	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.	

### SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

### GENERAL

***Clarification:*** *The use of powder actuated fasteners is prohibited on this project. Adhesive/epoxy or mechanical fasteners will be considered for use pending AE/Owner review based on the substrate material, substrate thickness, embedment, spacing and edge distance. Contractor shall submit manufacturer's recommended fastener for the specific substrate it is being attached to for approval prior to installation.*

### NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.



Project Manual and Drawing inquiries regarding the work should be directed to:

**CONTACT PERSON(S)**

Banner Associates, Inc.      Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

David Lorang

Architecture

davel@bannerassociates.com

**ATTACHMENTS**

- 1. None

A handwritten signature in blue ink, appearing to read "D. Lorang", is written over a horizontal line.

David Lorang  
Banner Associates, Inc.