

## ADDENDUM | No. 1

<b>PROJECT</b>	Cedar Shore Parking Lot Reconstruction
<b>BID DATE</b>	1:30 PM CDT April 19, 2017
<b>BID LOCATION</b>	Oacoma City Office 100 E. 3 <sup>rd</sup> Street Oacoma SD 57365
<b>ISSUE DATE</b>	April 13, 2017
<b>NOTICE</b>	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.

### SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

### DRAWINGS

The following additions, changes and clarifications have been made to the Drawings.

#### Drawing Sheet 3-GENERAL DETAILS.

##### ASPHALT PAVMENT DETAIL

##### *Clarification:*

NOTE: Asphalt Paving Contractor has the option to pave with one lift of asphalt to provide a compacted 3" mat. (Not 3' a noted)

### NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:

### CONTACT PERSON(S)



Banner Associates, Inc.    Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

Beth Niemeyer

Project Engineer

bethn@bannerassociates.com



Beth Niemeyer" (P.E.) #5482