Addendum #2

Project: Prentis Street Lift Station and Sanitary Sewer Improvements
Bid Date: 2:00 P.M., Local Time, March 14, 2017
Bid Location: Vermillion City Hall, 25 Center Street
Vermillion, SD 57069

Issue Date: March 13, 2017

Notice: Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.

SCOPE OF THIS ADDENDUM:
The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

PROJECT MANUAL:
The following additions, changes and clarifications have been made to the Project Manual.

Section 03 3216– Package Lift Station, Wet Well and Appurtenances,

Replace 2.1, F.5, *with the following:*

"5. The pumps shall be Fairbanks Model B5443K, Smith and Loveless 43BY: close-coupled with the X-peller, or prior approved equivalent."

Add the following to Section 4.2, A.1.g as an approved manufacturer/model for Bid Alternative #1.

"Fairbanks Model D5433WDK submersible with a 210T frame motor and bladeless impeller."

NOTE:
The Plan Holders List and addendums are available via the internet at http://www.bannerassociates.com by clicking on the Project Information link.

Addendum #2 (cont'd)

Project Manual and Drawing inquiries regarding the work should be directed to:

Contact Persons:

BANNER ASSOCIATES, INC.
Tanya Miller (Lift Station), Harold Holoch (Sanitary Sewer), Chad Bachman, (Controls), and Neil Eichstadt (Lift Station Site Plan)
Phone - (605) 692-6342
Toll Free – (855) 323-6342
Fax – (605)-692-5714
E-mail – tanyam@bannerassociates.com
haroldh@bannerassociates.com
chadb@bannerassociates.com
neile@bannerassociates.com

WEST PLAINS ENGINEERING, INC.
Mike Fisher (Electrical)
Phone- (605) 362-3753
Fax- (605) 362-3759
Email - mike.fisher@westplainsengineering.com

ATTACHMENTS

None

Tanya L. Miller, P.E. #8326