

ADDENDUM | No. 1

PROJECT	Well #6 Replacement 2017 – Volga, South Dakota
BID DATE	10:00 AM CDT August 31, 2017
BID LOCATION	Office of City of Volga 226 Kasan Avenue, Volga, SD 57071
ISSUE DATE	August 28, 2017
NOTICE	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.

SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

PRIOR APPROVALS

The following manufacturers of the items and materials have been added to the list of approved manufacturers. Listing of an item does not change the requirements of the specifications. Equipment furnished shall meet the materials and performance requirements as specified.

SECTION	DESCRIPTION	MANUFACTURER
331100	Gate Valve	American AVK

PROJECT MANUAL

The following additions, changes and clarifications have been made to the Project Manual.

Section 331100 – Site Piping, Section 2.1.F.2, page 331100-4

Delete: 2. Hydrant shall be furnished with a 3" MJ inlet.

Add: 2. Hydrant shall be furnished with a 2" threaded inlet.

Section 332100 – Production Well, Section 1.1.C.

Add: In addition to bucket drilling, rotary drilling of the production well will be allowed.



DRAWINGS

The following additions, changes and clarifications have been made to the Drawings.

Plan Sheet 5: 4.5" liquid filled pressure gauge will have a range of 0-100 psi.

NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:

CONTACT PERSON(S)

Banner Associates, Inc.

Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

Kristin Bisgard, P.E.

Project Manager

kristinb@bannerassociates.com



Kristin Bisgard, PE #6987