



ADDENDUM | No. 1

PROJECT	Timberline Addition Phase 4 Bid Package #2 – Utilities & Streets	
BID DATE	11:00 AM	Wednesday February 27, 2019
BID LOCATION	Banner Associates Office 409 22 nd Ave S. Brookings, SD 57006	
ISSUE DATE	February 25, 2019	
NOTICE	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.	

SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

PROJECT MANUAL

The following additions, changes and clarifications have been made to the Project Manual.

Section C-410– Bid Form

Item 35 - Pipe Bedding Material

Clarify:

This item is for bedding material for all pipe (Water, Sanitary, and Storm Sewer). See BMU Watermain specifications for materials as pea rock is no longer an accepted pipe bedding material.

Item 62 - 1” Curb Stop and Box

Clarify:

This item is for the curb stop only. It is not necessary to provide the curb stop box.

Item 69 - Connect to Existing Sanitary Sewer

Clarify:

Connect to Existing Sanitary Sewer shall be by core drill according to BMU Specifications.



NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:

CONTACT PERSON(S)

Banner Associates, Inc. Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

Justin Bucher

Staff Engineer

justinb@bannerassociates.com

ATTACHMENTS

None



Justin Bucher, PE #14123