

## ADDENDUM | No. 1

<b>PROJECT</b>	Baltic Street Improvements - 2018
<b>BID DATE</b>	10:00 AM Local Time May 1, 2018
<b>BID LOCATION</b>	Baltic City Finance Office 130 St. Olaf Avenue, Baltic, SD 57003-0327
<b>ISSUE DATE</b>	April 26, 2018
<b>NOTICE</b>	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.

### SCOPE OF THIS ADDENDUM

The following becomes a part of the original Project Manual and drawings, taking precedence over the items that may conflict. The Bidder shall note receipt and make acknowledgment of the Addendum on their bid form, incorporating its provision in their Bid.

### PROJECT MANUAL

The following additions, changes and clarifications have been made to the Project Manual.

#### Section C-410, Bid Form:

Page 9, Bid Items No. 46 and 47

**Clarify:**

Bid Item descriptions for the 6" Dia. and 4" Dia. Sanitary Sewer Pipe shall read **SDR 26** PVC instead of SDR 35 PVC.

#### Section 33 1000 – Water Utilities:

Part 2 – Products:

Paragraph 2.11 – Fire Hydrants;

**Delete:** A.3.d. American AVK

**Justification:**

Per Owner request, American AVK will not be an acceptable fire hydrant for this project.



**NOTE**

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:


**CONTACT PERSON(S)**

Banner Associates, Inc.                      Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

Scott A Mohror                                      Design Engineer                                      scottm@bannerassociates.com

**ATTACHMENTS**

- 1. None



---

Scott A Mohror, PE #8612