

ADDENDUM | No. 1

PROJECT	Vermillion UV Improvements
BID DATE	2:00 PM Central Time Zone 04/06/2022
BID LOCATION	Vermillion City Office 25 Center Street, Vermillion, SD 57069
ISSUE DATE	April 1, 2022
NOTICE	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.

SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

GENERAL

None.

PROJECT MANUAL

The following additions, changes and clarifications have been made to the Project Manual.

Section 26 2816 – ENCLOSED SWITCHES AND CIRCUIT BREAKERS

Add to Part 2, 2.1.B – Manufacturers:

5. Allen-Bradley

Section 46 6653 – OPEN CHANNEL UV EQUIPMENT

Replace Part 2, 2.2.1.7 with the following:

7. Electrical Supply to the Hydraulic System Center will be 2.5 KVA at 480 VAC 3Ph.

Replace Part 2, 2.2.1.9 with the following:

9. Electrical Supply to the System Control Center will be 1.8 KVA at 120 VAC 1Ph.



DRAWINGS

The following additions, changes and clarifications have been made to the Drawings.

Drawing Sheet D-100

General Notes:

Add: 4. OWNER TO PROVIDE INSTRUMENTATION AND CONTROLS FOR INTEGRATION OF NEW UV EQUIPMENT. CONTRACTOR TO PROVIDE OWNER WITH 2 WEEKS' NOTICE PRIOR TO INSTALLATION OF UV EQUIPMENT TO ALL OWNER TIME TO COORDINATE WITH INTEGRATOR FOR PROJECT NEEDS.

NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:

CONTACT PERSON(S)

Banner Associates, Inc. Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

Tanya Miller	Project Manager	tanyam@bannerassociates.com
Christa DeVries	Project Engineer	christad@bannerassociates.com

Subconsultant – PE Group Tel | Fax

Mark Joffer	Electrical Engineer	mark.joffer@pegrouppengr.com
-------------	---------------------	------------------------------

ATTACHMENTS

1. None



Tanya Miller (P.E.) #8326