

ADDENDUM | No. 1

PROJECT	Lake Norden WWTF and North Lift Station Improvements		
BID DATE	2:00 PM (Changed)	Local Time	September 27, 2022
BID LOCATION	Lake Norden City Hall 508 Main Ave, Lake Norden, SD 57248		
ISSUE DATE	September 13, 2022		
NOTICE	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.		

SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

PROJECT MANUAL

The following additions, changes and clarifications have been made to the Project Manual.

Section 00010– Advertisement

Delete:

The Bids must be prepared on bid forms supplied in the Bidding Documents and filed with City of Lake Norden, 508 Main Ave., Lake Norden, SD 57248 not later than 2:00 A.M., Local Time, September 27, 2022, at which time and place all Bids will be publicly opened and read aloud in the presence of the Bidders and their representatives.

Insert:

The Bids must be prepared on bid forms supplied in the Bidding Documents and filed with City of Lake Norden, 508 Main Ave., Lake Norden, SD 57248 not later than 2:00 P.M., Local Time, September 27, 2022, at which time and place all Bids will be publicly opened and read aloud in the presence of the Bidders and their representatives.

Section 33 3216 – Submersible Lift Station and Appurtenances

Section 1.6, A:

Delete:

Testing performed upon each pump shall include the following inspections:



Insert:

Pump performance testing shall include at a minimum, the following inspections:

Section 1.6, C:

Delete:

Each pump model shall be tested in accordance with the latest test code of the Hydraulic Institute (H.I.) at the manufacturers test facility to determine head vs. capacity and kilowatt draw required. Test results shall be provided prior to shipping the pumps(s).

Insert:

Pump performance testing shall include at a minimum, the following inspections:

Section 1.7, B:

Insert after number 15:

16. Pump performance testing results

Section 1.8, C:

Delete sentence:

The 5-year (or 10,000 hour) Warranty applies to the following Accessories if originally purchased with the pumps: Discharge Connection, Access Covers, HDL Valve, Guide Bar Bracket(s), and Pump Power Cable(s).

Section 2.1, K:

Delete Section 2.1 K "Wear Rings" in its entirety.

Section 2.12, A:

Delete:

The crane shall be equipped with both a hand winch and an electric winch. Lifting winches shall be a marine grade brake winches.

Insert:

The crane shall be equipped with an electric winch. Lifting winches shall be marine grade brake winches.



DRAWINGS

The following additions, changes and clarifications have been made to the Drawings.

Bid Schedule 2: Lake Norden North Lift Station and Gravity Sewer Improvements

Sheet H-2 – Existing Discharge Lift Station Removals & Improvements

Add: Note: Based on City records, existing pumps are Hydromatic S6L with a 6” discharge size.”

NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:

CONTACT PERSON(S)

Banner Associates, Inc. Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714

Deidre Beck Staff Engineer deidreb@bannerassociates.com

Beth Niemeyer Civil Project Engineer (Bid Schedule 2) bethn@bannerassociates.com

Dennis Rebelein Project Manager dennisr@bannerassociates.com


Todd Schultz Project Engineer (Bid Schedule 1) todds@bannerassociates.com

Power System Engineering, Inc. Tel 1-320- 978-8022

Josh Mulder Electrical Engineer (Bid Schedule 2) mulderj@powersystem.org

ATTACHMENTS

1. None.



Dennis Rebelein (P.E.) #8613