

ADDENDUM | No. 1

PROJECT	Ground Storage Reservoir Improvements - 2022
BID DATE	11:00 AM CDT 4/7/2022
BID LOCATION	City Offices 1001 E. 4 th Ave., Suite 301, Milbank, SD 57252
ISSUE DATE	3/31/2022
NOTICE	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.

SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

GENERAL

Clarification:

Full containment of the exterior is not a requirement. However, the contractor is responsible and liable for effects of their work (i.e. over-blast, dust, overspray, etc.). Best practices shall be used to minimize the inconvenience to neighbors.

PROJECT MANUAL

The following additions, changes and clarifications have been made to the Project Manual.

Section 09 9200– Steel Tank Coatings,

Section 3.3, E,

Add:

2. Exterior Surfaces

- a. Dry-abrasive blast clean all carbon steel surfaces exposed to exterior conditions to a near-white metal blast in accordance with NACE No. 2/SSPC-SP10.



NOTE

The Plan Holders List and Addendums are available on our website at <http://www.bannerassociates.com> by clicking on **View Bid Information / Project Name / Project Information** link.

Project Manual and Drawing inquiries regarding the work should be directed to:

CONTACT PERSON(S)

Banner Associates, Inc. Tel 1-605-692-6342 | Toll Free 1-855-323-6342 | Fax 1-605-692-5714


Adam Hanson, PE

Project Manager

adamh@bannerassociates.com

ATTACHMENTS

- 1. None



Adam Hanson, PE #10970